

**ADDENDUM # 1
BOONE COUNTY, MISSOURI
ST. CHARLES ROADWAY & DRAINAGE IMPROVMENTS
BID NO: 31 - 17JUN08**

ADDENDUM # 1

This addendum is issued in accordance with the Instruction to Bidders and hereby incorporated into and made a part of the Contract Documents.

Bidders are reminded that receipt of this addendum must be acknowledged and submitted with the attached Acknowledgment of Addendum Form and attached to your Bid Form.

Drawings and specifications for the above noted project and the work covered thereby are herein modified as follows, and except as set forth herein, otherwise remain unchanged and in full force and effect:

PROJECT REVISIONS / CLARIFICATIONS

- 1. BID DATE HAS BEEN CHANGED FROM JUNE 17TH TO JUNE 26TH AT 1:30 P.M. BIDS SHALL BE SUBMITTED TO PURCHASING DEPARTMENT NO LATER THAN 1:15 P.M TO BE CONSIDERED.**
- 2. TREE REMOVAL - All trees to be removed shall be marked with pink ribbon. Removal of trees shall be by cutting down and grinding stump to a minimum of 6" below ground / proposed ground level if in areas where ditching is required. If tree stump falls within 24" of flow line, tree shall be removed completely, roots included. Trees should be marked by June 19th.**
- 3. DITCHING - It is not the intent to build all ditches with 3:1 slopes. Proposed flow line distance from edge of roadway have been given with depths being the minimum required to create positive flow and provide cover over pipes as called out in specifications.**
- 4. Fencing - No fence removal or replacement is expected with this project unless required for staging of tree removal or grinding operations. This shall be considered incidental to removals.**

BIDDER has examined copies of all the Bidding Documents and of the following Addenda (receipt of all which is hereby acknowledged):

<u>DATE</u>	<u>ADDENDUM NUMBER</u>
_____	_____
COMPANY NAME: _____	_____
ADDRESS: _____	_____
PHONE NUMBER: _____	_____
AUTHORIZED REPRESENTATIVE: _____	_____