



BOONE COUNTY, MISSOURI
Request for Bid # 24-14APR09 – Sapp Building Erection at Boone County Fairgrounds

ADDENDUM #3 - Issued April 10, 2009

This addendum is issued in accordance with the Request for Bid and is hereby incorporated into and made a part of the Request for Bid Documents. Bidders are reminded that receipt of this addendum **MUST** be acknowledged and submitted with Bidder's *Response Form*.

Specifications for the above noted Request for Bid and the work covered thereby are herein modified as follows, and except as set forth herein, otherwise remain unchanged and in full force and effect:

1. Replace paragraph #7 in Addendum #2 with the following:

7. Replace any reference in the bid specification for "simple saver" insulation to "reinforced vinyl back" insulation. The roof insulation shall be 6" reinforced vinyl backed R-19 insulation and the wall insulation shall be reinforced vinyl back R-13 insulation.

By: 
Melinda Bobbitt, CPPB

OFFEROR has examined copy of Addendum #3 to Request for Bid # **24-14APR09 – Sapp Building Erection at Boone County Fairgrounds**, receipt of which is hereby acknowledged:

Company Name: _____
Address: _____

Phone Number: _____ Fax Number: _____

Authorized Representative Signature: _____ Date: _____

Authorized Representative Printed Name: _____