



BOONE COUNTY, MISSOURI
Request for Bid #: 43-31JUL09 – Replace Trane Roof Top Unit

ADDENDUM #2 - Issued July 30, 2009

This addendum is issued in accordance with the Introduction and General Conditions of Bidding in the Request for Bid and is hereby incorporated into and made a part of the Request for Bid Documents. Bidders are reminded that receipt of this addendum should be acknowledged and submitted with Bidder's *Response Form*.

Specifications for the above noted Request for Bid and the work covered thereby are herein modified as follows, and except as set forth herein, otherwise remain unchanged and in full force and effect:

I. The County received the following questions and has provided the following responses:


Question 1: What options are needed on the unit: i.e. economizer, smoke detector, hail guards, disconnect, etc.

Response: The options needed are economizer and power exhaust.

Question 2: What is the model # of the T-state to check compatibility with the new unit?

Response: VAYSENS019C.

It is the obligation of the bidder to verify any and all information.

By: 
Melinda Bobbitt, CPPB
Director of Purchasing

OFFEROR has examined copy of Addendum #2 to Request for Bid # 43-31JUL09 – **Replace Trane Roof Top Unit** receipt of which is hereby acknowledged:

Company Name: _____

Address: _____

Phone Number: _____ Fax Number: _____

Authorized Representative Signature: _____ Date: _____

Authorized Representative Printed Name: _____