

**Bid Tabulation: 44-17AUG10 - Clean Agent Fire Suppression System**

4.7. PRICING	Fire Safety Inc.	Simplex Grinnell LP
4.7.1. Option 1 includes the mounting of the control panel outside the Printer Room to the north of the east door of the Information Technology Department. In addition, Bidders shall bid assuming the dampers will be provided by the County. After award, the County will coordinate with the awarded bidder to appropriately add the dampers where needed into the main project.	\$75,333.00	\$75,234.00
4.7.2. Option 2 includes the mounting of the control panel outside the Printer Room to the north of the east door of the Information Technology Department. In addition, all bidders shall assume they need to provide dampers to the elections storage and any ductwork that travels over the computer/printing areas as part of their bid. The Records Vault should have an existing damper in place and therefore one does not need to be added.	\$80,073.00	\$76,474.00
4.7.3. Option 3 includes mounting the control panel as close to the tanks as possible with the enunciator placed outside the door of the Printer Room in the Information Technology Department. In addition, Bidders shall bid assuming the dampers will be provided by the County. After award, the County will coordinate with the awarded bidder to appropriately add the dampers where needed into the main project.	\$76,501.00	\$75,952.00
4.7.4. Option 4 includes mounting the control panel as close to the tanks as possible with the enunciator placed outside the door of the Printer Room in the Information Technology Department. In addition, all bidders shall assume they need to provide dampers to the elections storage and any ductwork that travels over the computer/printing areas as part of their bid. The Records Vault should have an existing damper in place and therefore one does not need to be added.	\$81,241.00	\$77,310.00
4.7.5. List Brand and Model Bid	Kidde Fire Systems	Ansul Sapphir
4.7.6. Name of clean agent chemical used	Novec 1230	Novec 1230
4.7.7. Inspection: State a firm, fixed cost for an annual inspection	\$915.00	\$709.00
Inspection: State a firm, fixed cost for a semi-annual inspection	\$250.00	\$1,419.00
4.8. Work will begin ____ days after receipt of Notice to Proceed	5 working days as required to meet construction	TBD
4.9. Will will be completed ____ days after receipt of Notice to Proceed	as required to meet construction schedule	TBD
4.10. Physical address of repair facility	Wood River, IL	Earth City, MO
4.11. Warranty	1 yr. parts & labor + 2 years parts	2 years
	Note: Fire Safety included Terms and Conditions - some of which we will not agree to such as #4, #5, #7, #8, #9, #10, #11, #16, #17 (our attorney will have to review the rest for non-compliance).	
References Provided	Yes	Yes
Bid Bond	Yes	Yes
Statement of Bidder's Qualifications	Yes	Yes
Anti-Collusion Statement	Yes	Yes
Signature and Identity of Bidder	Yes	Yes
Bidder's Acknowledgment	Yes	Yes
Debarment Certification	No	Yes
Work Authorization	Yes	Yes
Addendums #1, #2, #3	Yes	Yes
<b>No Bids</b>		
Legacy Business Group Inc.		
Material Bonds		