



BOONE COUNTY, MISSOURI
Request for Bid #: 05-28FEB11 – Chiller Installation

ADDENDUM #2 - Issued February 23, 2011

This addendum is issued in accordance with the Introduction and General Conditions of Bidding in the Request for Bid and is hereby incorporated into and made a part of the Request for Bid Documents. Bidders are reminded that receipt of this addendum should be acknowledged and submitted with Bidder's *Response Form*.


Specifications for the above noted Request for Bid and the work covered thereby are herein modified as follows, and except as set forth herein, otherwise remain unchanged and in full force and effect:

- I. During the Pre-Bid conference a question was asked and an answer given as follows:**

“What are some of the other manufacturers you would accept?”

The answer was given as follows:

“Carrier and York are some of the acceptable manufacturers.”

By: 
Tyson Boldan
Buyer

OFFEROR has examined copy of Addendum #1 to Request for Bid # **05-28FEB11 – Chiller Installation**, receipt of which is hereby acknowledged:

Company Name: _____

Address: _____

Phone Number: _____ Fax Number: _____

Authorized Representative Signature: _____ Date: _____

Authorized Representative Printed Name: _____