



BOONE COUNTY, MISSOURI
Request for Bid #: 51-26SEP12 – HVAC Services Term and Supply
ADDENDUM #1 - Issued September 26, 2012

This addendum is issued in accordance with the Bid Response Page in the Request for Bid and is hereby incorporated into and made a part of the Request for Bid Documents. Bidders are reminded that receipt of this addendum should be acknowledged and submitted with Bidder's *Response Form*.


Specifications for the above noted Request for Bid and the work covered thereby are herein modified as follows, and except as set forth herein, otherwise remain unchanged and in full force and effect:

1.) The county received the following question and is providing a response below:

Question: The bid request proposes quarterly maintenance at the Public Works building on highway 63. They are requesting premium pleated filters. How are they defining premium?

Response: The County defines any filter rated 30% efficiency or above to be a premium filter.

2.) Change Bid Opening Date to: Monday, October 1, 2012.

By: 
Amy Robbins
Senior Buyer

OFFEROR has examined copy of Addendum #1 to Request for Bid **51-26SEP12 – HVAC Services Term and Supply**, receipt of which is hereby acknowledged:

Company Name: _____

Address: _____

Phone Number: _____ Fax Number: _____

Authorized Representative Signature: _____ Date: _____

Authorized Representative Printed Name: _____