



BOONE COUNTY, MISSOURI
Request for Proposal #: 08-24FEB15 – Used Telecommunication Equipment Shelter

ADDENDUM #3 - Issued February 11, 2015

This addendum is issued in accordance with the Bid Response Page in the Request for Proposal and is hereby incorporated into and made a part of the Request for Proposal Documents. Bidders are reminded that receipt of this addendum should be acknowledged and submitted with Bidder's *Proposal Response*.

Specifications for the above noted Request for Proposal and the work covered thereby are herein modified as follows, and except as set forth herein, otherwise remain unchanged and in full force and effect.

The County received the following questions and with this Addendum #3 the following responses are provided. **Note to Bidders: This Addendum #3 replaces Addendum #2 previously issued.**

The following questions revolve around Section 3.2 point # 5 which states that there will be electrical service, lighting, wall mount HVAC's, etc...

- A. Please provide the size of HVAC (12,000 Btu/hr = 1 ton) required to cool your equipment heat loads? If you don't know what size, please provide the equipment heat loads.
- B. Please provide the Amperage size of the electrical that is available at the site (100, 200, 300, 400, etc...).
- C. Will 32 Watt fluorescent bulbs be acceptable?
- D. Do the specifications mean "cable ladder"?

Response to all above:

- 1. Two (2) 5-Ton wall pack heat/AC units, nom 208/240 VAC single phase operation with min/max thermostat and alternator operation.
- 2. "H" configuration of 15" overhead raceway suspended from ceiling and anchored to walls.
- 3. Nominal 120/240 VAC single phase 200A electrical panel.
- 4. Space and provision to add automatic transfer switch and outboard main breaker.
- 5. High output fluorescent lighting running continuous length x 2 and width x 2 of shelter ceiling.
- 6. Wall receptacles spaced +/- 4' around perimeter, ceiling receptacles front and back of racks spaced +/- 2'
- 7. Cable/waveguide entry panel for 6 x 6 pattern of nominal 4" boots/cushions.
- 8. Smoke/Fire alarm with summary contacts.
- 9. Ground bar with halo; all metallic items bonded.

By:

Elizabeth Sanders, CPPB
Senior Buyer, Purchasing

OFFEROR has examined copy of **Addendum #3** to Request for Proposal# **08-24FEB15 – Used Telecommunication Equipment Shelter**, receipt of which is hereby acknowledged:

Company Name: _____

Address: _____

Phone Number: _____ Fax Number: _____

E-mail: _____

Authorized Representative Signature: _____ Date: _____

Authorized Representative Printed Name: _____