



BOONE COUNTY, MISSOURI
**Request for Bid #: 63-15OCT15 – Radio Tower Foundation and Site Construction for
the Emergency Communication Center**


ADDENDUM #3 - Issued October 16, 2015

This addendum is issued in accordance with the RFP Response Page in the Request for Bid and is hereby incorporated into and made a part of the Request for Bid Documents. Offerors are reminded that receipt of this addendum **should be acknowledged** and submitted with Offeror's *Response Form*.

Specifications for the above noted Request for Bid and the work covered thereby are herein modified as follows, and except as set forth herein, otherwise remain unchanged and in full force and effect.

- 1) Add to Section 2.02.a: "On drawing ME1 gravel to be used for compound and service road is 1" clean rock. Vegetation barrier shall be Propex brand Geotex 200ST or equivalent. On detail B/ME1 welded 6 x 6 mesh specified for slab may be replaced with #4 @ 12" OC tied steel mat. On drawing ME1 the dimension from SE tower leg to face of equipment building shall be reduced from 10' to 5'. At site, the center of constructed tower shall be placed 8'6" east of marked pin."
- 2) Add to Section 1.08: "Construction entrance to the site shall be from the north. No construction equipment traffic is permitted on entry drive or south drive around Boone County Sheriff's Department."

By:


Melinda Bobbitt, CPPO, CPPB
Director of Purchasing

OFFEROR has examined **Addendum #3** to Request for Bid # 63-15OCT15 – *Radio Tower Foundation and Site Construction for the Emergency Communication Center* receipt of which is hereby acknowledged:

Company Name: _____

Address: _____

Phone Number: _____ Fax Number: _____

E-mail: _____

Authorized Representative Signature: _____ Date: _____

Authorized Representative Printed Name: _____