



BOONE COUNTY, MISSOURI
Request for Bid #: 25-19MAY16
Waters Edge Drainage Improvements-2016

ADDENDUM #1 - Issued May 16, 2016

This addendum is issued in accordance with the Request for Bid Notice to Bidders and is hereby incorporated into and made a part of the Request for Bid Documents. Offerors are reminded that receipt of this addendum **should** be acknowledged and submitted with Offeror's *Response Form*.

Specifications and Plans for the above noted Request for Bid and the work covered thereby are herein modified as follows, and except as set forth herein, otherwise remain unchanged and in full force and effect:

1. Clarification of Questions Received:

Question: Can the cul-de-sacs in the neighborhood be used as staging and storage areas for equipment and materials?

Answer: Yes, the Contractor may use the cul-de-sacs for staging and storage purposes. However, the Contractor shall not block access to any private driveways within or near the cul-de-sac. Contractor shall be responsible for the protection of equipment and material by use of cones or other devices. The Contractor shall leave as much usable area open in the cul-de-sac as practical for the turning around of vehicles.

Question: What are the sizes and the material of the existing stormwater pipes?

Answer: All existing stormwater pipes to be removed are corrugated metal pipes (CMP). Their sizes are as follows:

Existing Pipe Diameter Sizes

Inlet A-B: 18"

Inlet B-C: 24"

Inlet C-D: 30"

Ditch-Inlet D: 42"

Inlet D-E: 42"

Culvert near Inlets F & G: 42"

Cross road pipe between existing inlets: 30"

Outlet pipe from existing inlet: 30"

Inlet H-Area Inlet: 18"

Area Inlet-Inlet I: 24"

Ditch-Inlet J: 18"

Inlet J-K: 18"

Question: Can all the trees within the grading limits be removed on the north side of the road near Inlets F & G?


Answer: If a tree is within the grading limits and is in conflict with the project, then it shall be removed. If there is a doubt or question about a tree during construction, the Contractor shall seek direction from the County.

By: 

Phil Fichter, Buyer
Boone County Purchasing

Approved: Micah Taylor
Professional Engineer
MO Lic. # PE-2013019123

Boone County Resource Management
MO Engineering Corp. # N/A
801 E. Walnut, Room 315
Columbia, Missouri 65201
Phone: 573-886-4480
Fax: 573-886-4340



OFFEROR has examined copy of Addendum #1 to Request for Bid # 25-19MAY16 – Waters Edge Drainage Improvements-2016, receipt of which is hereby acknowledged:

Company Name: _____

Address: _____

Phone Number: _____ Fax Number: _____

Authorized Representative Signature: _____ Date: _____

Authorized Representative Printed Name: _____