



BOONE COUNTY, MISSOURI
Request for Bid #: 37-30JUN16
Mexico Gravel Road Bridge

ADDENDUM #1 - Issued June 23, 2016

This addendum is issued in accordance with the Request for Bid Notice to Bidders and is hereby incorporated into and made a part of the Request for Bid Documents. Offerors are reminded that receipt of this addendum **should** be acknowledged and submitted with Offeror's *Response Form*.

Specifications and Plans for the above noted Request for Bid and the work covered thereby are herein modified as follows, and except as set forth herein, otherwise remain unchanged and in full force and effect:

1. Clarification of Question At Pre-Bid Conference:

Questions

1. There is a bid item for Compaction Testing, but are there other testing requirements (i.e. asphalt, concrete, etc.)? If so, how will other testing requirements be paid for?

Answer: Concrete and asphalt testing is spelled out in specs as contractor responsibility. Please see section TS.8.

2. Plan calls for galvanized piles for the bridge, but also says 3' below pile cap shall be wire brushed and painted with bituminous paint. Is it necessary to paint since the pile is galvanized? Concern is paint will not stick due to the galvanized coating. Does contractor have to try and remove the galvanized coating and paint?

Answer: The piles will not be required to painted. Please see section O of the job special provisions.

3. Does County have a borrow pit available to the contractor for project?

Answer: No

4. Is the steel piling for the water gap supposed to be galvanized?

Answer: No

5. What is the depth the steel piling for water gap shall be driven?

Answer: Typically 10'


6. How was the quantity on the bid sheet for steel piling derived? What were the assumptions and does it include the piles needed for the water gap?

Answer: Quantity was derived from interpreting the subsurface investigation. Quantity does not include water gap.

7. Is there a reason NTP is mid-August? Can it be sooner?

Answer: Yes.

By:



Phil Fichter, Buyer
Boone County Purchasing

Approved: Shannon Howe
Professional Engineer
MO Lic. # E-2000162117

Boone County Resource Management
MO Engineering Corp. # N/A
801 E. Walnut, Room 315
Columbia, Missouri 65201
Phone: 573-886-4480
Fax: 573-886-4340



OFFEROR has examined copy of Addendum #1 to Request for Bid # 37-30JUN16 – Mexico Gravel Road Bridge, receipt of which is hereby acknowledged:

Company Name: _____

Address: _____

Phone Number: _____ Fax Number: _____

Authorized Representative Signature: _____ Date: _____

Authorized Representative Printed Name: _____