



BOONE COUNTY, MISSOURI  
Request for Bid #: 27-08JUN17-Concrete Rehab-2017

ADDENDUM #1 - Issued June 2, 2017

This addendum is issued in accordance with the Request for Bid Notice to Bidders and is hereby incorporated into and made a part of the Request for Bid Documents. Offerors are reminded that receipt of this addendum **should** be acknowledged and submitted with Offeror's *Response Form*.

Specifications and Plans for the above noted Request for Bid and the work covered thereby are herein modified as follows, and except as set forth herein, otherwise remain unchanged and in full force and effect:

1. Question: Can Geotex 4x4UF be considered an approved equal to the Mirafi RS580i?


Answer: Yes, Geotex 4x4UF by Propex will be considered an approved equal to Mirafi RS580i for this project.

2. Question: Can Notice to Proceed date be pushed back?


Answer: Official Notice to Proceed will be established by the Contractor and County at the Pre-Construction meeting, however it is the intention of the County to have this project completed this year. As such the Contractor will be given the Contract Time as specified in the bid or until November 6, 2017, whichever comes first, to complete the project. If construction proceeds past the Contract Time or November 6<sup>th</sup>, liquidated damages will begin to be assessed at \$500.00 per Working Day.

3. Special Provision #69 states that geotextile shall be overlapped a minimum of 36" at all longitudinal and transverse seams. Contractor may choose to forgo overlapping requirements by having factory installed sewn seams.
4. Error was found in the Base Bid Form. Base Bid shall indicate a unit of **3** for bid item "Inlet Throat, Remove & Replace." A revised Base Bid Form is attached to this Addendum and shall be used in the bid submittal.
5. Special Provision #46 shall read, "Excavation bid item does not include any excavation needed for curb and gutter replacement."
6. Location of the Bid Opening has been modified. New location of Bid Opening is as follows:

Bid Opening  
Thursday, June 8, 2017 at 1:30 p.m.  
**Conference Room 301**  
801 E. Walnut  
Columbia, MO, 65201

By:   
Phil Fichter, Buyer  
Boone County Purchasing

Approved: Micah Taylor  
Professional Engineer  
MO Lic. # PE-2013019123  
  
Boone County Resource Management  
MO Engineering Corp. # N/A  
801 E. Walnut, Room 315  
Columbia, Missouri 65201  
Phone: 573-886-4480  
Fax: 573-886-4340



OFFEROR has examined copy of Addendum #1 to Request for Bid # 27-08JUN17 Concrete Rehab-2017 Georgetown & Lake of the Woods Subdivision, receipt of which is hereby acknowledged:

Company Name: \_\_\_\_\_

Address: \_\_\_\_\_  
\_\_\_\_\_

Phone Number: \_\_\_\_\_ Fax Number: \_\_\_\_\_

Authorized Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_

Authorized Representative Printed Name: \_\_\_\_\_

**BASE BID FORM (REVISED 6-1-2017)**  
**CONCRETE REHAB-2017**  
**GEORGETOWN AND LAKE OF THE WOODS SUBDIVISIONS**

Description	Qty.	Unit	Unit Price	Total
MOBILIZATION	LS	1	\$	\$
TRAFFIC CONTROL/PHASING	LS	1	\$	\$
EROSION CONTROL	LS	1	\$	\$
MATERIAL TESTING	LS	1	\$	\$
REMOVAL, CURBSIDE OBSTRUCTIONS, REPLACEMENT INCLUDED	LS	1	\$	\$
REMOVAL, EXISTING CONCRETE PAVEMENT, SAW CUTTING INCLUDED	SY	10221	\$	\$
EXCAVATION	CY	2268	\$	\$
CURB & GUTTER, ROLLBACK, REMOVE & REPLACE	SY	559	\$	\$
INLET THROAT, REMOVE & REPLACE	EA	3	\$	\$
MIRAFI RS580i GEOTEXTILE	SY	10186	\$	\$
1 1/2" MINUS AGGREGATE BASE, 6" THICK	SY	3860	\$	\$
1 1/2" MINUS AGGREGATE BASE, 10" THICK	SY	5612	\$	\$
1 1/2" MINUS AGGREGATE BASE, 14" THICK	SY	714	\$	\$
PCC PAVEMENT, 4000 PSI, 6" THICK	SY	42	\$	\$
BITUMINOUS BASE COURSE, 6 1/2" THICK	TON	3655	\$	\$
TACK COAT (TRACKLESS TACK OR APPROVED EQUAL)	SY	20372	\$	\$
ASPHALT SURFACE COURSE, BP-2, 1 1/2" THICK	TON	844	\$	\$
CRACK SEALING	LF	7572	\$	\$
RESTORATION	LS	1	\$	\$
<b>Base Bid Total</b>				<b>\$</b>

Optional Asphalt Cement Price Index (Circle One)

Accept

Do Not Accept