



ADDENDUM #1 to RFB#48-13AUG19

Boone County Purchasing

613 E. Ash Street, Room 113

Columbia, MO 65201

Robert Wilson, Buyer

Phone: (573) 886-4393 – Fax: (573) 886-4390

Email: rwilson@boonecountymo.org

BOONE COUNTY, MISSOURI

Request for Bid 48-13AUG19 – Generator Inspection Services - Term & Supply

ADDENDUM # 1 - Issued July 29, 2019

Prospective bidders are hereby notified of the following clarification to Request for Bid 48-13AUG19:

1. The County received the following questions and is providing a response:

To be able to price the following I will need to know the kilowatts.

N/A	JJC	Roger L Perry Juvenile Justice Center, 5565 N Roger Wilson Memorial Dr, Columbia MO	Kohler	35HZ82	355479		NG/Propane
N/A	Jail	Boone County Jail, 2121 County Drive, Columbia MO	Kohler	300R07D81	265098		Diesel
18600	Jail-PH	Boone County Jail, Pump House, 2121 County Drive, Columbia MO	Briggs & Stratton	40375			Propane

Road & Bridge: Contact: Greg Edington 573-449-8515; Billing Address: 5551 Tom Bass Road South, Columbia, MO 65201

16762	R&B	5551 Tom Bass Road South, Columbia MO	Generac	SD350 8734780100	2005232		Diesel
-------	-----	---------------------------------------	---------	------------------	---------	--	--------

I also wanted to clarify that you are looking for quarterly service on all generators, with an additional annual report and not quarterly pricing and annual pricing on all generators. Last but not least, are you looking for a 2-hour load bank or a different amount of time?

The JJC unit is a 35kW, the big jail unit is a 300kW, and the Briggs unit is a 10kW. The Generac at the Tom Bass site should be a 350 kW.

To the other questions: We would want both quarterly and annual pricing for each generator. The plan is that each department will make their own schedule, and some may only want an annual inspection and load test while another will need quarterly inspections. It also affords the County the opportunity to switch from quarterly to annual if need be with a fixed price.

Also, yes, a 2-hour load bank is what is anticipated in this bid.

This addendum is issued in accordance with the Request for Bid and is hereby incorporated into and made a part of the Request for Bid Documents. Offerors are reminded that receipt of this addendum should be acknowledged and submitted with Offeror's Bid Response.

Specifications for the above noted Request for Bid and the work covered thereby are herein modified as proceeds, and except as set forth herein, otherwise remain unchanged and in full force and effect.

By: 
Robert Wilson, Buyer
Boone County Purchasing

The BIDDER has examined **Addendum #1** to Request for Bid #48-13AUG19 – **Generator Inspection Services - Term & Supply** receipt of which is hereby acknowledged:

Company Name: _____

Address: _____

Telephone: _____ Fax: _____

Print Name: _____ Title: _____

Signature: _____ Date: _____

Contact Name and E-Mail Address to receive documents for electronic signature in *DocuSign*:
